



Results of Test: WYC 370282

M H Joinery Products PLC

Unit 11 Parrett Way
Colley Lane Industrial Estate
Bridgwater
Somerset
TA6 5LD

This document confirms that performance testing was conducted from 11 August to 17 October 2016. Testing was conducted to the following standards:

- BS 6375 Part 1: 2009 Performance of windows and doors – Part 1: Classification for weathertightness and guidance on selection and specification
- PAS 24: 2012 Enhanced security performance requirements for doorsets and windows in the UK.

The following results were achieved:

Product tested	Woburn MK II Casement Window		
Summary of testing procedure			Result
	Test Standard	Classification Standard	
Air permeability	BS EN 1026: 2000	BS EN 12207: 2000	600Pa Class 4
Watertightness	BS EN 1027: 2000	BS EN 12208: 2000	900Pa Class 9A
Wind resistance	BS EN 12211: 2000	BS EN 12210: 2000	2400Pa (Class CE2400)
Exposure category		BS 6375: Part 1: 2009	2400
PAS 24: 2012 Clauses C.4.3, C.4.4.2, C.4.4.3, C.4.5, C.4.6 and C.4.7			Pass

Passed PAS 24: 2012 for the requirements of both key locking and non-key locking handles

The results relate only to the specimens tested, as detailed in the technical specification

Issued By:
Mark West
Laboratory Manager

Authorised By:
Mark Garfield
Deputy Laboratory Manager
Issue date: 12 January 2017

Exova (UK) Ltd (trading as Exova)

Chiltern House, Stocking Lane, Hughenden Valley, High Wycombe, HP14 4ND, UK

Tel: 01494 569800 Fax: 01494 564895

Web: www.exova.com Email: europa@bmtrada.com

This document is confidential and remains the property Exova (UK) Ltd



1762