



Certificate of Test: Chilt/P08106

This certificate is awarded to:

MH Joinery Products

Unit 11, Parrett Way
Colley Lane Industrial Estate
Bridgwater
Somerset
TA6 5LD

This document confirms that performance testing was conducted from 10 February 2009 to 13 February 2009. Testing was conducted to the following standards:-

- BS 7950:1997 Amendments 1, 2 and 3 Specification for enhanced security performance of windows for domestic applications.
- BS 6375 Part 1:2004 Performance of windows and doors - Part 1: Classification for weathertightness and guidance on selection and specification.
- And BS 6375 Part 2:1987 Amendments 1 and 2 Performance of windows - Part 2. Specification for operation and strength characteristics. The following results were achieved

Product tested	Woburn Window		
Summary of testing and classification			
	Test Standard	Classification standard	Result
Air permeability	BS EN 1026: 2000	BS EN 12207: 2000	600Pa (Class 4)
Watertightness	BS EN 1027: 2000	BS EN 12208: 2000	100Pa (Class 3A)
Wind resistance	BS EN 12211: 2000	BS EN 12210: 2000	1200Pa (Class 3)
Exposure category	BS 6375: Part 1: 2004		1200
BS 6375: Part 2: 1987, clauses A.2, A.3, A.5, A.6, A.7 and A.8			Pass
BS 7950: 1997- tested to clauses A.4, A.5, A.6, A.7 and A.8			Pass

Air leakage at 50pa was 0.2m³/h positive pressure and 0.4m³/h negative pressure. The perimeter length of opening light was 9.25m

Passed BS 7950: 1997 for both key removable and thumbturn locks

The results relate only to the specimens tested, as detailed in technical specification document number Chilt/P08106/tec1

S.J. Smith
Steve Smith – Test Engineer

Date: 15-04-2009

Vincent Kerrigan
Vincent Kerrigan - Technical Manager

Date: 15-04-2009

Chiltern Dynamics

Chiltern House, Stocking Lane, Hughenden Valley, High Wycombe, HP14 4ND, United Kingdom

Tel: 01494 569800 Fax: 01494 564895

Web: www.chilternfire.co.uk

Email: cif@chilternfire.co.uk

Page 1 of 5



1762

This document is confidential and remains the property of Chiltern International Fire Ltd