



# Certificate of Test: Chilt/P09013/01

This certificate is awarded to:

## MH Joinery Products PLC

Unit 11 Parrett Way  
Colley Lane Industrial Estate  
Bridgwater  
Somerset  
TA6 5LD

This document confirms that performance testing was conducted from 13 February 2009 to 16 March 2009. Testing was conducted to the following standards:-

- PAS 23-1: 1999, Amendments 1, 2, 3 and 4 and Corrigendum 1, General performance requirements for door assemblies - Single leaf external door assemblies to dwellings,
- PAS 24-1: 2007 Enhanced security performance requirements for door assemblies - Part 1: Single and double leaf, hinged external door assemblies to dwellings
- And BS 6375 Part 1:2004 Performance of windows and doors - Part 1: Classification for weathertightness and guidance on selection and specification. The following results were achieved

Product tested	Woburn Door (Inward Opening)		
Summary of testing procedure			Result
	Test Standard	Classification Standard	
Air permeability	BS EN 1026: 2000	BS EN 12207: 2000	600Pa (Class 3)
Watertightness	BS EN 1027: 2000	BS EN 12208: 2000	50Pa (Class 2A)
Wind resistance	BS EN 12211: 2000	BS EN 12210: 2000	800Pa (Class A2)
Exposure category		BS 6375: Part 1: 2004	800X
PAS 24-1: 2007 - Clauses A.4, A.5, A.6, A.7, A.9, A.10 and A.11			Pass
PAS 23-1: 1999 - Clause 6.3, 6.4, 6.5, 6.6, 6.7, 6.8, 6.9, 6.10, 6.11 and 6.14			Pass

**Passed PAS 24-1:2007 for both key removable and thumbturn locks**

The results relate only to the specimens tested, as detailed in the technical specification Chilt/P09013/tec1

*S.J. Smith*  
Steve Smith – Test Engineer

Date: *07-05-2009*

*Vincent Kerrigan*  
Vincent Kerrigan – Technical Manager

Date: *07-05-2009*

Chiltern Dynamics

Chiltern House, Stocking Lane, Hughenden Valley, High Wycombe, HP14 4ND, United Kingdom

Tel: 01494 569800 Fax: 01494 564895

Web: [www.chilternfire.co.uk](http://www.chilternfire.co.uk)

Email: [cif@chilternfire.co.uk](mailto:cif@chilternfire.co.uk)

Page 1 of 5



1762

This document is confidential and remains the property of Chiltern International Fire Ltd